

<b>Fire Alarm Statistics 2008</b>					
<b>Date:</b>	<b>Fire Alarm</b>	<b>Location</b>	<b>Cause</b>	<b>Injuries/Deaths</b>	<b>Property Damage</b>
Jan. 10, 2008	Smoke sensor	25 College St.	Unknown	0	\$ -
Jan. 15, 2008	Unknown	53 Park St.	Unknown	0	\$ -
Jan. 16, 2008	Smoke sensor	Sykes Hall	Radiator	0	\$ -
Jan. 19, 2008	Smoke sensor	78 Park St.	Fire Exting	0	\$ -
Jan. 26, 2008	Smoke sensor	Hulett/Jencks Hall	Unknown	0	\$ -
Jan. 27, 2008	Smoke sensor	Hulett/Jencks Hall	Burned food	0	\$ -
Feb. 12, 2008	Smoke sensor	Reiff Hall	Burned food	0	\$ -
Feb. 13, 2008	Pull Station	ODY Library	Trigger by accident	0	\$ -
Feb. 13, 2008	N/A	84 Park St.	Maintenance	0	\$ -
Feb. 15, 2008	Smoke sensor	Hulett/Jencks Hall	Fire Exting	0	\$ -
Feb. 16, 2008	Pull Station	Carnegie Hall	Someone pulled it	0	\$ -
Feb. 17, 2008	Pull Station	Sykes Hall	Someone pulled it	0	\$ -
Feb. 24, 2008	Smoke sensor	25 College St.	Discharged Fire Ext.	0	\$ -
Feb. 28, 2008	Smoke sensor	50 Park St.	Smoke machine	0	\$ -
March. 2, 2008	Smoke sensor	Dana Dining Hall	Grill Smoke	0	\$ -
March. 3, 2008	Smoke sensor	Sykes Hall	Burned food	0	\$ -
March. 6, 2008	Heat stations	Brown Hall	Water Leak	0	\$ -
March. 8, 2008	Smoke sensor	Dana Dining Hall	Unknown	0	\$ -
March. 12, 2008	Smoke sensor	Sykes Hall	Cooking	0	\$ -
March. 14, 2008	Smoke sensor	50 Park St.	Cooking	0	\$ -
March. 17, 2008	Heat stations	Lee Hall	Broken Hot water Line	0	\$ -
March. 17, 2008	Heat stations	Lee Hall	Unknown	0	\$ -
April. 04, 2008	Smoke sensor	48 Park St.	Cooking	0	\$ -
April. 05, 2008	Smoke sensor	Sykes Hall	Discharged Fire Ext.	0	\$ -
April. 12, 2008	Smoke sensor	Dean Eaton Hall	Faulty sensor	0	\$ -
April. 12, 2008	Smoke sensor	Whitman Hall	Discharged Fire Ext.	0	\$ -
April. 17, 2008	Smoke sensor	48 Park St.	Steam	0	\$ -
April. 18, 2008	Smoke sensor	Lee Hall	Fire works in rm 118-119	0	\$ -
April. 20, 2008	Smoke sensor	Sykes Hall	Pot Smoke	0	\$ -
April. 24, 2008	Smoke sensor	Griffith Art Center	Maintenance	0	\$ -
May. 01, 2008	Smoke sensor	58 E. Main St.	Burned food	0	\$ -

May. 05, 2008	Smoke sensor	50 Park St.	Burned food	0	\$	-
May. 09, 2008	Pull Station	Whitman Hall	Someone pulled it	0	\$	-
May. 31, 2008	Pull Station	Dean Eaton Hall	Someone pulled it	0	\$	-
May. 31, 2008	Smoke sensor	58 Park St.	Unknown	0	\$	-
June. 6, 2008	Smoke sensor	Rebert Hall	Contractor personnel	0	\$	-
June. 6, 2008	Smoke sensor	Rebert Hall	Humidity	0	\$	-
June. 6, 2008	Smoke sensor	Whitman Hall	Humidity	0	\$	-
June. 20, 2008	Smoke sensor	Rebert Hall	Unknown	0	\$	-
July. 13, 2008	Fire panel	Johnson Hall	Board malfunction	0	\$	-
July. 14, 2008	Fire panel	Johnson Hall	Board malfunction	0	\$	-
August. 09, 2008	Smoke sensor	Dana Dining Hall	Cooking	0	\$	-
August. 24, 2008	Smoke sensor	Gaines Hall	Unknown	0	\$	-
August. 29, 2008	Smoke sensor	48 Park St.	Burned food	0	\$	-
August. 30, 2008	Smoke sensor	48 Park St.	Burned food	0	\$	-
September. 03, 2008	Smoke sensor	58 Park St.	Cooking	0	\$	-
September. 03, 2008	Smoke sensor	Sykes Hall	Cooking	0	\$	-
September. 14, 2008	Smoke sensor	Sykes Hall	Unknown	0	\$	-
September. 15, 2008	Smoke sensor	5 University Ave.	Smoking	0	\$	-
September. 18, 2008	Pull Station	3 University Ave.	Test	0	\$	-
September. 18, 2008	Pull Station	5 University Ave.	Test	0	\$	-
September. 18, 2008	Pull Station	17 College St.	Test	0	\$	-
September. 18, 2008	Pull Station	25 College St.	Test	0	\$	-
September. 18, 2008	Pull Station	53 Park St.	Test	0	\$	-
September. 18, 2008	Pull Station	ATO	Test	0	\$	-
September. 18, 2008	Smoke sensor	48 Park St.	Burned food	0	\$	-
September. 20, 2008	Smoke sensor	Townhouse 404	Burned food	0	\$	-
September. 27, 2008	Pull Station	Hulett/Jencks Hall	Student pulled alarm	0	\$	-
September. 29, 2008	Smoke sensor	54 Park St.	Burned food	0	\$	-
October. 05, 2008	Smoke sensor	Hulett/Jencks Hall	Burned food	0	\$	-
October. 05, 2008	Smoke sensor	Sykes Hall	Discharged Fire Ext.	0	\$	-
October. 08, 2008	Smoke sensor	Dean Eaton Hall	Steam bathroom	0	\$	-
October . 25, 2008	Smoke sensor	Hulett/Jencks Hall	Mechanical	0	\$	-
October. 27, 2008	Smoke sensor	48 Park St.	Burned eggs	0	\$	-
November. 12, 2008	Smoke sensor	58 Park St.	Unknown	0	\$	-

Nobember 06, 2008	Smoke sensor	Payson Hall	Water pressure	0	\$	-
November. 08, 2008	Smoke sensor	Johnson Hall	Unknown	0	\$	-
November. 12, 2008	Smoke sensor	48 Park St.	Cooking	0	\$	-
November. 13, 2008	Smoke sensor	1 Lincoln St.	Cooking	0	\$	-
November. 15, 2008	Smoke sensor	Dean Eaton Hall	Knocked off ceiling	0	\$	-
November. 17, 2008	Smoke sensor	48 Park St.	Cooking	0	\$	-
November. 17, 2008	Smoke sensor	48 Park St.	Burned food	0	\$	-
November. 20. 2008	Smoke sensor	48 Park St.	Hair spray	0	\$	-
December. 04, 2008	Smoke sensor	Townhouses	Burned food	0	\$	-
December. 08, 2008	Smoke sensor	Lee Hall	Faulty alarm	0	\$	-
December. 17, 2008	Smoke sensor	Student Center	Kitchen smoke	0	\$	-
December. 23, 2008	Smoke sensor	Payson Hall	Unknown	0	\$	-
December. 27, 2008	Smoke sensor	Sykes Hall	Cooking	0	\$	-